

ENERGY

Overview of global experience with biomass co-firing and coal to biomass conversions

Technology, fuel supply, byproducts and regulation, economics

Jan Middelkamp, Marcel Cremers


06 September 2018

IEA Bioenergy



Industry consolidation

2,500 energy experts help customers throughout the electrical power industry realize efficient, reliable and clean energy for today and the future.



Global reach – local competence



150

years

350

offices

100

countries


12,500

employees

100,000

customers

Our vision: global impact for a safe and sustainable future



Biomass (co-)firing in power generation

Sustainability targets and CO₂ reduction – the role of biomass

POLICY MAKERS AND REGULATORS

(National) targets,
incentives

MARKETS

Power market,
alternative sustainable
technologies,
dispatchable power >
BIOMASS

UTILITIES

Business case,
implementation

Biomass co-firing and full conversion

What is considered high percentage co-firing



- Is it **>10%** ...
- or is it **>30%** ...
- or is it **>50%** ...
- or is it **>80%**

Fuel coal to biomass conversion



TECHNOLOGY & EXPERIENCES



FUEL SELECTION




REGULATIONS & BY-PRODUCTS



ECONOMICS & CO₂ FOOTPRINT

Technology and experiences

Applied biomass co-firing routes



Each co-firing route has its own (unique) operational requirements and constraints and specific demands on the fuel quality

Experiences with biomass co-firing and repowering

UNITED KINGDOM	▪ Drax, Ferrybridge, Fiddler's Ferry, Tilbury, Ironbridge, Lynemouth ▪ Various fuels: wood, crops, residues
DENMARK	▪ Avedøre, Amager, Ensted, Studstrup ▪ Wood chips, wood pellets, straw(pellets)
BELGIUM	▪ Rodenhuize, Les Awirs, Ruien ▪ Mainly wood-based fuels
THE NETHERLANDS	▪ Geertruidenberg, Rotterdam, Nijmegen, Borssele ▪ Wood pellets, agro- and industrial residues, meat and bone meal
CANADA	▪ Atikokan, Thunder Bay ▪ Wood pellets, steam explosion pellets



Power plant components affected by biomass (co-)firing

STORAGE

- Piles
- Bunkers

LOGISTICS

- Conveyors
- Feeders
- Mills

STEAM PLANT

- Burners
- Furnace section
- Convection section

FLUE GAS

- Flue gas cleaning system
- Stack



Power plant components affected by biomass (co-)firing

STORAGE

- Dedicated storage or storage on coal yard?
- Dust emissions and explosion risks!
- Odor...

LOGISTICS AND MILLING

- Coal conveyors suitable?
- Low co-firing: pre-mixing and co-milling
- High co-firing: modified or dedicated mills/classifiers
- Dust explosion risks
- Primary air temperature

STEAM PLANT (PULVERIZED FUEL BOILER)

- Particle size > combustion
- Deposition on burners; slagging and fouling
- Soot blowers, water jets, sonic horns, explosive cleaning
- Corrosion risks

FLUE GAS CLEANING


- SO₂ and dust (no major issues)
- No_x
 - ✓ dependent on fuel
 - ✓ SCR deactivation

Fuel selection

Fuel selection criteria

Low co-firing rate or EFLH	High co-firing rate or EFLH
Low investments	Higher investments
More expensive fuel	Cheaper fuel


ELIGIBILITY OF BIOMASS FUEL



Meeting subsidy requirements

- Sustainability criteria
- Additional requirements

REGULATORY AND PERMIT ASPECTS



Biomass waste?

- Emission requirements

Biomass pre-treatment and upgrading



Steam explosion pellets
(courtesy Arbaflame)



Wood pellet production
(courtesy Enviva)

Torrefied pellet production
(courtesy Torrcoal)



Choose your co-firing fuel

	Wood chips	Wood pellets	Torrefaction pellets	Steam explosion pellets	Coal
Moisture content (% wt)	30 – 45	7 – 10	1 – 5	? - 11	10 – 15
Calorific value (MJ/kg)	9 – 12	15 – 16	20 – 24	17 – 19	23 – 28
Volatiles (% db)	70 – 75	70 – 75	55 – 65	70 – 80	15 – 30
Fixed carbon (% db)	20 – 25	20 – 25	28 – 35	17 - ?	50 – 55
Bulk density (kg/l)	0.2 – 0.25	0.55 – 0.75	0.75 – 0.85	0.65 – 0.78	0.8 – 0.85
Energy density (GJ/m ³)	2.0 – 3.0	7.5 – 10.4	15.0 – 18.7	11.0 – 15.0	18.4 – 23.8
Dust	Limited	Average	Average/high	Average/high	Limited/average
Hydroscopic properties	Hydrophilic	Hydrophilic	Hydrophobic	Hydrophobic	Hydrophobic
Biological degradation	Yes	Yes	No	Potentially	No
Milling requirements	Special	Classic/special	Classic	Classic	Classic
Handling properties	Special	Special/easy	Easy	Easy	Easy
Transport cost	High	Average	Low	Low/Average	Low

Regulatory and by-products

Meeting emission limits

Dependent on local regulations and emission standard

ESP/baghouse filter

- ash content
- resistivity

FGD

- low SO₂, high HCI load

SCR

- deactivation
- use of coal fly-ash

Co-firing of

- clean wood: limited impact on emissions
- specific types of biomass: potential impact on emissions

What about the ashes (IEA Task 32 study)

Application	Requirements/challenges
Disposal/landfill	Minimum standard (Directive 2008/98/EC) and preferred solution in many cases
Use in forestry	Leaching of heavy metals
Fertilizer/soil amendment	Leaching of heavy metals, strict legislation
Addition to compost	Up to 3-5%, REACH registration in EU
Cement, raw meal constituent	Requirements in bi-lateral contracts
Cement and concrete fillers	EN 450 standard applicable in EU
Asphalt concrete filler	Dependent on technical product regulation
Underground mining	Particularly for bottom ashes
Civil engineering, road construction	Particularly for bottom ashes

Economics and carbon footprint

Costs of co-firing and repowering (for illustration only)

Imaginary case:
100 MW_e,
40% efficiency,
5,000 equivalent
full load hours

Additional costs
from co-firing:

- Fuel costs
- Capital costs
- O&M costs

Revenues from
co-firing:

- CO₂ credits
- Subsidies

Case: 100 Mw_e, 40% efficiency, 5,000 equivalent full load hours

GENERAL DATA

Annual power production:
500,000 MWh/a

Annual fuel consumption:
4.5 PJ/a

INCREASED FUEL COSTS (co-firing)

Coal:

3 EUR/GJ

Wood pellets:

9 EUR/GJ

Δ Fuel costs:

6 EUR/GJ

Annual Δ fuel cost:

27 MEUR/a

Δ Specific fuel costs: 54 EUR/MWh

Case: 100 Mw_e, 40% efficiency, 5,000 equivalent full load hours

CAPITAL EXPENSES

200 kEUR/MW_{th}
installed > **50 MEUR**

Capital expenses:

5 MEUR/a

(linear depreciation,
10 years)

O&M COSTS

6% of investment costs:
3 MEUR/a

TOTAL CAPITAL AND O&M

8 MEUR/a

Δ Specific capital and
O&M costs:

16 EUR/MWh

Case: 100 Mw_e, 40% efficiency, 5,000 equivalent full load hours

Revenues

- CO₂ emission reduction: 0.5 Mt/a
- CO₂ @ 10 EUR/t: 5 MEUR/a (current)
- Δ specific costs = -10 EUR/MWh


Δ overall costs = 54 + 16 - 10 = 60 EUR/MWh (8,000 JPY/MWh)

Typical range in detailed business cases: 50 - 80 EUR/MWh → minimum subsidy level required

Co-firing of waste streams:

- Low or negative price
- Limited co-firing rate; additional emission standards

Supply chain (CO₂ per MWh of electricity generation)



Conclusion

- **Biomass co-firing and full coal to biomass conversion are proven technology**
- **Biomass fuels**
 - ✓ **white wood pellets commodity fuel**
 - ✓ **strong developments on processed biomass**
 - ✓ **opportunity fuels and biomass waste streams**
- **Biomass selection based on required co-firing rate and EFLH**
- **Impact on emissions to be addressed case by case**
- **Utilization of ashes requires further development**
- **Economics: prices of biomass, investments, subsidies, CO₂ price**
- **Carbon footprint: discussions regarding sequestration in forests**

Biomass can provide dispatchable capacity to support intermittent solar and wind power

Thank you for your attention

Jan Middelkamp

jan.middelkamp@dnvgl.com

+31 26 356 2483

www.dnvgl.com

SAFER, SMARTER, GREENER

The trademarks DNV GL®, DNV®, the Horizon Graphic and Det Norske Veritas® are the properties of companies in the Det Norske Veritas group. All rights reserved.